

iSERV Measured Data Analysis by HVAC Component and Activity - Cyprus

By

Margarita Assimakopoulos , Maria Argyriou

02/06/2014

Intelligent Energy – Europe (IEE) SAVE Project

May 7th 2011 to May 6th 2014

Project websites:

Main website: <http://www.iservcmb.info>

Database website: <http://www.iservcmb.eu>

The sole responsibility for the content of this report lies with the authors. It does not necessarily reflect the opinion of the European Union. Neither the EACI nor the European Commission are responsible for any use that may be made of the information contained therein.

iSERV Measured Data Analysis – Cyprus

iSERV Project Team

| | | | |
|---|--|--|--|
| <p>Welsh School of Architecture, Cardiff University UK (Project co-ordinator)</p> | | <p>K2n Ltd UK</p> | |
| <p>MacWhirter Ltd UK</p> | | <p>National and Kapodistrian University of Athens Greece</p> | |
| <p>University of Porto Portugal</p> | | <p>Politecnico di Torino Italy</p> | |
| <p>Université de Liège Belgium</p> | | <p>Univerza v Ljubljani Slovenia</p> | |
| <p>University of Pecs Hungary</p> | | <p>Austrian Energy Agency Austria</p> | |
| <p>REHVA EU</p> | | <p>CIBSE UK</p> | |

Contents

| | |
|---|----|
| iSERV Measured Data Analysis by HVAC Component and Activity - Cyprus | 1 |
| Contents..... | 3 |
| 1 Introduction | 4 |
| 2 Overall HVAC Component and Activities Overview plus Data Summaries..... | 5 |
| 2.1 Overall HVAC Components and Activities Summary | 6 |
| 2.2 Summary of measured monthly energy use by HVAC Sub-component type servicing a given activity 7 | |
| 2.3 Summary Conclusions..... | 9 |
| 3 Detailed Data Summary and Analysis | 10 |
| 3.1 Measured data accuracy..... | 10 |
| 3.2 Summary of measured monthly energy use by HVAC component type and Sub-type..... | 11 |
| 4 References | 13 |

iSERV Measured Data Analysis – Cyprus

1 Introduction

This report presents the measured HVAC component and end use activity data obtained for Cyprus during the iSERV project. This particular report presents the recorded energy use information by floor area and HVAC components for each activity type within the iSERV system.

A separate report presents the energy use information by the floor area served only. The reports have been separated for reasons of size and clarity, as well as due to the more controversial nature of the initial benchmarks used for apportionment by activity, as reported in this document.

iSERV Measured Data Analysis – Cyprus

2 Overall HVAC Component and Activities Overview plus Data Summaries

This section covers the overall description of the HVAC components as given in the iSERV spreadsheets for Cyprus as well as summarising the measured data from the more detailed parts of this report.

Table 1a - Number of meters serving each activity

| Activity type | Electricity | Gas | Heat | Water |
|-----------------------|-------------|-----|------|-------|
| Cellular Office Area | 6 | | | |
| Laboratory | 4 | | | |
| Open Plan Office Area | 4 | | | |

2.1 Overall HVAC Components and Activities Summary

iSERV Measured Data Analysis – Cyprus

Table 1 summarises the data collected for the HVAC Components and the iSERV Activity types available in Cyprus. It can be seen that the HVAC components in this country service 3 total activity types with areas ranging in size from 625 to 2045 m². There was an average of 1meter available for each system analysed.

The most frequently encountered component type in this country was Terminal Units and Air Handling Units. The number following the comma for each component type shows how many had sub-metering which addressed their energy use. This sub-metering could be either dedicated to the component or cover a series of HVAC components.

Table 1 – Overall Systems Summary for Cyprus showing numbers of components and meters associated with each activity type. For the components columns, the first number shows total components associated with each activity. The number after the comma shows the number of submeters associated with this component type.

| Activity type | Floor Area / m2 | # of spaces | Air Handling Units | All-in-One Systems | Cold Generators | Heat Generators | Heat Pump | Heat Recovery | Heat Rejection | Humidifiers | Pumps | Terminal Units |
|-----------------------|-----------------|-------------|--------------------|--------------------|-----------------|-----------------|-----------|---------------|----------------|-------------|-------|----------------|
| Cellular Office Area | 2045 | 9 | 6 | | | | 4 | | | | | 10 |
| Laboratory | 625 | 3 | 6 | | | | 3 | | | | | 4 |
| Open Plan Office Area | 840 | 1 | 6 | | | | 3 | | | | | 4 |

iSERV Measured Data Analysis – Cyprus

2.2 Summary of measured monthly energy use by HVAC Sub-component type servicing a given activity

The tables in this section provide the ranges of average and standard deviation monthly energy consumptions found in different HVAC sub-component types servicing the noted end use activity across Cyprus.

What it does illustrate is how the consumption of each sub-component varies with the month of the year.

iSERV Measured Data Analysis – Cyprus

2.2.1.1 Activity types – monthly energy use/m² summary by Air Handling Units- Electricity Consumption

This table shows the measured ranges of monthly energy use recorded for this sub-component type.

Table 2 – Measured average monthly energy consumption (standard deviation) in kWh/m² by Air Handling Units - Electricity Consumption servicing the given activity for Cyprus

| Activity type | ANNUAL TOTAL | JANUARY | FEBRUARY | MARCH | APRIL | MAY | JUNE | JULY | AUGUST | SEPTEMBER | OCTOBER | NOVEMBER | DECEMBER |
|-----------------------|--------------|---------------|--------------|--------------|---------------|-----|------|------|--------|-----------|---------|----------|----------|
| Cellular Office Area | - | 0.1838 (0.00) | 0.1489(0.00) | 0.0922(0.00) | 0.1215(0.00) | | | | | | | | |
| Laboratory | - | 0.573 (0.00) | 0.4643(0.00) | 0.2875(0.00) | 0.3788 (0.00) | | | | | | | | |
| Open Plan Office Area | - | 0.2056 (0.00) | 0.1666(0.00) | 0.1032(0.00) | 0.1359(0.00) | | | | | | | | |

2.2.1.2 Activity types – monthly energy use/m² summary by Heat Pump - Electricity Consumption

This table shows the measured ranges of monthly energy use recorded for this sub-component type.

Table 3 – Measured average monthly energy consumption (standard deviation) in kWh/m² by Heat Pump - Electricity Consumption servicing the given activity for Cyprus

| Activity type | ANNUAL TOTAL | JANUARY | FEBRUARY | MARCH | APRIL | MAY | JUNE | JULY | AUGUST | SEPTEMBER | OCTOBER | NOVEMBER | DECEMBER |
|-----------------------|--------------|----------------|----------------|----------------|-----------------|-----|------|------|--------|-----------|---------|----------|----------|
| Cellular Office Area | - | 1.909 (1.5206) | 1.4196 (1.111) | 0.991 (0.7249) | 1.675 (1.9902) | | | | | | | | |
| Laboratory | - | 1.909(1.5206) | 1.4196 (1.111) | 0.991 (0.7249) | 0.6986 (0.4711) | | | | | | | | |
| Open Plan Office Area | - | 1.909(1.5206) | 1.4196 (1.111) | 0.991 (0.7249) | 0.6987(0.4711) | | | | | | | | |

2.2.1.3 Activity types – monthly energy use/m² summary by Terminal Units - Electricity Consumption

This table shows the measured ranges of monthly energy use recorded for this sub-component type.

Table 4 – Measured average monthly energy consumption (standard deviation) in kWh/m² by Terminal Units - Electricity Consumption servicing the given activity for Cyprus

| Activity type | ANNUAL TOTAL | JANUARY | FEBRUARY | MARCH | APRIL | MAY | JUNE | JULY | AUGUST | SEPTEMBER | OCTOBER | NOVEMBER | DECEMBER |
|-----------------------|--------------|-----------------|----------------|-----------------|----------------|-----|------|------|--------|-----------|---------|----------|----------|
| Cellular Office Area | - | 0.2444 (0.0409) | 0.2304 (0.061) | 0.1948 (0.0826) | 0.4334 (0.261) | | | | | | | | |
| Laboratory | - | 0.1969(0.00) | 0.1595 (0.00) | 0.0988(0.00) | 0.1301 (0.00) | | | | | | | | |
| Open Plan Office Area | - | 0.1969(0.00) | 0.1595 (0.00) | 0.0988 (0.00) | 0.1301(0.00) | | | | | | | | |

iSERV Measured Data Analysis – Cyprus

2.3 Summary Conclusions

Unfortunately there is not a lot of data for the Cyprus buildings so a lot of the tables in the report are empty.

iSERV Measured Data Analysis – Cyprus

3 Detailed Data Summary and Analysis

This section examines each System in detail, along with summaries of the measured data in the first column of each table. The summaries are used in the overview section in this report.

The data is considered at the level of consumption by HVAC component using the following metrics: kWh/m² by month.

The data in this section is derived directly from the HERO database and is normalised to the floor areas allocated to each HVAC component within the iSERV spreadsheet for each building.

3.1 Measured data accuracy

The actual floor areas are expected to be between -1 to +4% of the value recorded in the iSERV spreadsheet, and the maximum expected error in the read for each electricity and gas meter is $\pm 2\%$ [Knight 2014]. For heat meters the expected errors are around - 10% based on studies of the actual performance of installed heat meters in Sweden [Jomni 2006] and observations of installation practice in real buildings.

The findings presented here should be read with these potential inaccuracies in mind.

iSERV Measured Data Analysis – Cyprus

3.2 Summary of measured monthly energy use by HVAC component type and Sub-type

The data is considered at the level of consumption by HVAC component using the following metrics: kWh/m² by month.

The tables in this section provide the ranges of average and standard deviation monthly energy consumptions found in different HVAC sub-component types across Cyprus. This data does not take into account the activities being serviced.

3.2.1.1 Sub-component – monthly energy use/m² summary by Air Handling Units-Supply and Extract Electricity Consumption

This table shows the measured ranges of monthly energy use recorded for this sub-component type.

Table 5 – Measured average monthly energy consumption (standard deviation) in kWh/m² by Air Handling Units – Supply and Extract- monthly Electricity Consumption for Cyprus

| Component Sub- type | ANNUAL TOTAL | JANUARY | FEBRUARY | MARCH | APRIL | MAY | JUNE | JULY | AUGUST | SEPTEMBER | OCTOBER | NOVEMBER | DECEMBER |
|---------------------|--------------|------------------|------------------|------------------|------------------|-----|------|------|--------|-----------|---------|----------|----------|
| Supply and Extract | - | 0.3215 (0.00) | 0.2605 (0.00) | 0.1613 (0.00) | 0.2125 (0.00) | | | | | | | | |

3.2.1.2 Sub-component – monthly energy use/m² summary by Heat Pump-Air Source reverse cycle – cooling optimised- Electricity Consumption

This table shows the measured ranges of monthly energy use recorded for this sub-component type.

Table 6 – Measured average monthly energy consumption (standard deviation) in kWh/m² by Heat Pump – Air Source reverse cycle – cooling optimised - monthly Electricity Consumption for Cyprus

| Component Sub- type | ANNUAL TOTAL | JANUARY | FEBRUARY | MARCH | APRIL | MAY | JUNE | JULY | AUGUST | SEPTEMBER | OCTOBER | NOVEMBER | DECEMBER |
|--|--------------|-------------------|-------------------|-------------------|-------------------|-----|------|------|--------|-----------|---------|----------|----------|
| Air Source reverse cycle – cooling optimised | - | 1.909 (1.5206) | 1.4196 (1.111) | 0.991 (0.7249) | 1.675 (1.9902) | | | | | | | | |

iSERV Measured Data Analysis – Cyprus

3.2.1.3 Sub-component – monthly energy use/m² summary by Terminal Unit – Fan Coils – 2 or 4 tubes - Electricity Consumption

This table shows the measured ranges of monthly energy use recorded for this sub-component type.

Table 7 – Measured average monthly energy consumption (standard deviation) in kWh/m² by Terminal Unit – Fan Coils – 2 or 4 tubes - monthly Electricity Consumption for Cyprus

| Component Sub- type | ANNUAL TOTAL | JANUARY | FEBRUARY | MARCH | APRIL | MAY | JUNE | JULY | AUGUST | SEPTEMBER | OCTOBER | NOVEMBER | DECEMBER |
|--------------------------|--------------|--------------------|-------------------|--------------------|-------------------|-----|------|------|--------|-----------|---------|----------|----------|
| Fan Coils – 2 or 4 tubes | - | 0.2444 (0.0409) | 0.2304 (0.061) | 0.1948 (0.0826) | 0.4334 (0.261) | | | | | | | | |

iSERV Measured Data Analysis – Cyprus

4 References

Knight I P – “Measured Energy Use and Power Demands in European HVAC Components”, CIBSE ASHRAE Technical Symposium, Dublin, Ireland, 3-4 April 2014.

Jomni Y, v. Deventer J and Delsing J – “Comparing heat measurement accuracy of a new adaptive algorithm with existing heat meters in accordance to the Swedish test standard”, 10th International Symposium on District Heating and Cooling, September 3 – 5, 2006.