



**Inspection of
HVAC systems
through
continuous
monitoring and
benchmarking**

www.iservcmb.info



Benchmarking HVAC system energy performance – the European iSERV project

Dr Ian Knight

iSERV Coordinator

www.iservcmb.info

AUE Conference

September 2012

The sole responsibility for the content of this presentation lies with the authors. It does not necessarily reflect the opinion of the European Union. Neither the EACI nor the European Commission are responsible for any use that may be made of the information contained here.

HVAC energy efficiency - practice



→ When trying to run the services in a building in an energy efficient manner the basic question to be answered is:

‘Is the energy being consumed by an HVAC system reasonable for the activities it serves?’

→ Asking the question is easy – providing a convincing answer is more difficult

Energy use in HVAC systems



- ➔ Energy use in buildings is defined as the energy being provided to each building. This can be through the billing meter, from district systems or generated within or on the building itself.
- ➔ Energy use in HVAC systems is similarly about ALL the items that consume energy in the HVAC system – not just the headline components of chillers or boilers.
- ➔ In the face of being required to procure ‘nZEB’ buildings by 2019, this talk discusses why it is important that we revisit the way in which we account for the energy use of buildings. The talk concentrates on the HVAC component of this energy use as this is the one most controllable by the energy manager



WHY IT IS IMPORTANT WE REDUCE HVAC ENERGY USE

Why is Europe interested in the energy use of HVAC systems?



Equipment	Electrical consumption as % of total EU 2007 Elec use
Air conditioning units and chillers	0.75
Fans in ventilation systems	3.34
Pumps / circulators	1.81
Space and Hot Water Heating	5.23
TOTAL	11.13%

EC Joint Research Centre, Institute for Energy, 2009

- At this level of energy consumption, HVAC systems must be a key contributor towards energy savings in the EU
- EU GDP in 2007 ~ €13,500Bn. Electricity costs ~ €1,300 – 2,600Bn or 10 – 20% of the GDP. Fossil fuel costs on top of this.
- A 10% HVAC saving is worth ~ €15 - 30Bn at €0.1 – 0.2 per kWh, or 0.1 – 0.2% of GDP, therefore primary motive for savings is improved energy security though the boost to GDP would be welcome.
- Does NOT include savings from reducing fossil fuel energy use.

Legislative requirements




- ➔ The UK's Part L comes from local transposition of the requirements of the 2002 European Energy Performance of Buildings Directive (EPBD). The EPBD was recast in 2011 and the forthcoming Part L (October 2013 onwards) will reflect the changes made.
- ➔ The EPBD arose because the market was not delivering the savings needed in the buildings sector to help meet long-term energy and environmental security concerns in Europe.
- ➔ The EPBD, and its recast, is the primary legislation affecting all EU Member States' building energy use legislation
- ➔ In addition the UK implements further legislation such as CRC

Implementation of the EPBD



- Introduced 2002, the EPBD became law on 04/01/2006
- The recast EPBD becomes law between 01/01 and 01/07/2013



- Taken from the REHVA Journal – March 2012

Which parts of the EPBD affect HVAC systems?



- ➔ The EPBD has specific requirements for the treatment of HVAC systems within EU MS.
- ➔ They are referred to as Technical Systems within the EPBD and have specific requirements for Inspection
- ➔ There is a requirement within the recast EPBD for all new buildings to be nZEB by 30/12/2020, and Public Buildings by 30/12/2018.
- ➔ This will have a major impact on HVAC systems, which will have a key role to play in achieving these targets.

Who decides the targets?




- ➔ Pressure bodies; Industry Lobbying; Academia; Other...
- ➔ Rarely however do the end users help set these targets.
- ➔ We therefore end up with 'unusual' issues where reality and theory do not always match up e.g. recent 'impossibility' to build Nat Vent buildings under Part L
- ➔ iSERV proposes that reality should form part of the basis for targets – not calculations alone. It also wants to reduce legislative requirements on end users who can demonstrate they are already meeting realistic targets for their buildings

HARMONAC: 2007 - 2010



- An IEE European project, which obtained sub-hourly information on energy use in HVAC systems from 42 EU Systems
- It showed the electrical energy use of HVAC systems is typically 30 – 40% of the building total electrical use.
- HVAC generally accounts for > 90% of non-electrical energy use
- Produced data on in-use energy consumption in HVAC components
- All findings at: www.harmonac.info



Annual energy balance – One Wood Street, London

The crux of the issue...



- The two London, UK HQ Office buildings monitored in HARMONAC were very close in terms of occupancy type and activities.
- One was new at the start of monitoring and used the very latest 'advice' on trying to achieve a low energy design (variable speed drives, low fresh air rates, chilled beams, low energy daylight linked lighting, etc)
- The other was a 1988 building with that era plant which was gradually being updated.
- They both used a nearly identical amount of HVAC energy per m².
- **Even the 'experts' don't really understand the implications of their design decisions on achieved 'in-use' energy performance**
- The benefits of 'energy efficient' HVAC **components** can potentially be negated by poor design and operating decisions.
- **Poor design choices can be locked into HVAC system energy performance for decades**

Current advice on achieving energy efficiency in HVAC systems




- With little information available on energy efficiency achieved in practice, then professional advice tends to be based on theoretical considerations
- The history of HVAC systems until recently has been about providing the 'right' conditions, not reducing energy use, so we are starting from a low evidence base when trying to improve energy in use.
- Many HVAC system configurations are possible. How to provide advice?
- For an HVAC system to work **efficiently** the interactions between the heating, cooling, humidification and ventilation components are crucial, as are their interactions with the climate, building fabric and occupancy.
- HARMONAC showed that a major contributor to poor energy consumption was a lack of meaningful feedback on performance.
- **It is not yet possible to say “Just do this” and achieve an energy efficient HVAC system**

Automatic monitoring – prospects for savings



- HARMONAC showed mandatory **Inspections identified about 37% of the energy savings shown to be present by the more detailed sub-hourly monitoring**
- The overall **average energy savings possible in the Case Study AC systems investigated were assessed as being between 35 – 40%, or around 10% of the primary energy use of the buildings in which they were located**



HARMONAC Impact



- ➔ HARMONAC's results led to HVAC Inspection requirements changing from Article 9 in the original EPBD to Articles 15 and 16 in the recast EPBD. These new articles allow alternatives to physical Inspection based on automatic monitoring. The project also led to a more general emphasis on automatic monitoring and control systems in the recast EPBD as a whole
- ➔ This **transfer of emphasis from 'reacting' to legislation to 'actively' demonstrating efficiency** is likely to be reinforced as we move towards 2020.

WHY BUILDINGS USE ENERGY

Buildings are for activities



- ➔ We construct environments (buildings) in which to undertake activities. Energy use is a direct effect of these activities.
- ➔ Energy efficiency is therefore always bound by the requirements of these activities. Providing the wrong environment needed for the activities is counterproductive to the wider needs of the organisation
- ➔ Energy efficiency can therefore only be properly evaluated when put into the context of the activities served

What we need to know is:

‘How much energy is it appropriate to use for a given activity?’

What affects energy use?

Role of the occupant



- ➔ A number of studies (IEE Projects including HARMONAC, Carbon Trust, etc) have shown that engaging end users can achieve significant savings (up to 30%) in electricity use.
- ➔ The energy balance equation discussed in the following slides clearly shows the importance of the internal gains, and hence activities, in the overall building energy demands.
- ➔ Any good energy management system must therefore provide **Responsibility and Accountability** for energy use, along with ongoing **Engagement** of the people responsible for this use.

What affects energy use?

Building energy losses and gains



→ Energy use in buildings arises as a result of the continuous interactions between the following energy components:

$$Q_i + Q_s \pm Q_c \pm Q_v \pm Q_{st} \pm Q_{lat} \pm Q_m = 0$$

→ Q_i – internal gains

→ Q_s – solar gains

→ Q_c – conduction losses or gains

→ Q_v – ventilation losses or gains

→ Q_{st} – energy stored or released from the fabric

→ Q_{lat} – latent energy losses or gains, and

→ Q_m – mechanical energy used to make up any overall energy losses or gains to achieve required internal conditions

New and Near Zero Energy Buildings



- ➔ New and nZEB need a design balance to be struck between the energy components to minimise energy consumption
- ➔ Q_c and Q_{st} in new and nZEB are usually negligible compared to Q_v and Q_i (and Q_s if not well handled). Q_{lat} can be significant dependent on location and activities.
- ➔ Assuming Q_c , Q_{st} and Q_{lat} can usually be ignored, minimising Q_m requires good control of Q_v to balance Q_i where possible

$$Q_i \pm Q_v (+ Q_s) = \pm Q_m$$


- ➔ Demand Controlled Ventilation (DCV) and other techniques for controlling Q_v are therefore a major focus for reducing energy use in new buildings, along with understanding of internal gains Q_i

Accounting for Energy Use - Assigning Responsibility



- Building energy use splits logically into two areas:
- The **energy use consumed and required by the occupants** of the building when undertaking the activities for which the building is operated
 - The **consequent energy use of these activities** i.e. energy consumed by the services to provide the conditions required for the activities.

→ Practically we therefore need to assess the energy use in buildings from these two viewpoints



The transition to nZEB



- ➔ The reality check of what it is actually possible to achieve in operational buildings is crucial for the transition to nZEB as clearly some activities cannot be zero energy by their nature.
- ➔ It is important we do not have inappropriate legislation for meeting 'nZEB' status that does not recognise these issues, otherwise the legislation becomes impossible to implement.
- ➔ iSERVcmb intends to provide a first version of these 'in-use' benchmarks as part of the transition to nZEB buildings.
- ➔ The CIBSE Technical Committee met on the 12th July 2012 to formulate a definition of nZEB buildings for consideration by the EC.

Definition of nZEB?



→ CIBSE's proposed definition of a nZEB is:

'Technically and reasonably achievable energy use of > 0 kWh/(m² a) primary energy, achieved with a combination of energy efficiency measures and renewable energy technologies.'


'Footnote: 'reasonably achievable' means by comparison with national energy use benchmarks appropriate to the activities served by the building, or any other metric that is deemed appropriate by each EU Member State.'

→ As a full Partner in iSERVcmb, CIBSE intends to use the benchmark ranges derived from iSERV as part of its professional guidance to its members of what is 'reasonably achievable'. Guidance should arrive from 2014 onwards.

nZEB from Jan 2019 onwards



- ➔ Near Zero Energy Buildings (nZEB) will be required from 2019
- ➔ Still not clear what the final legal definition of nZEB will be




- taken from REHVA proposals for nZEB definition June 2012

Are nZEB feasible?



- ➔ German housing energy use trends appear to suggest 'Yes'
- ➔ Not yet clear how far we can reduce energy use in non-domestic buildings due to the wide variety of activities, but iSERV should help provide achievable target ranges



- Source: REHVA Journal March 2012

Building Information Modelling (and Management)



- ➔ BIM(M) is inevitably how building information will be organised in the future, and will be useful in many aspects of Facilities Management.
- ➔ However, modelling is not yet a reliable way of predicting energy use in buildings as the input parameters needed for accurate prediction are too difficult to obtain once you put people and activities into buildings.
- ➔ Real 'in-use' data is required to enable prediction techniques to move forward using statistically valid datasets which enable us to fill in some of the 'input' gaps.
- ➔ As noted already, this data should distinguish between activity and service use to be most useful.

ISERV CMB - A PRACTICAL PROCEDURE FOR BENCHMARKING ENERGY USE IN HVAC SYSTEMS

iSERVcmb – the continuous monitoring and benchmarking of HVAC systems



→ www.iservcmb.info May 2011 – May 2014

→ At €3.3M iSERVcmb is the largest EC project ever funded under the IEE funding stream

→ iSERVcmb's philosophy can be summarised as:

→ **You can't manage what you don't measure**

- We need data to understand HVAC system operation

→ **You can't control what you don't understand**

- Often, little information exists on the HVAC system components, where they serve, the system design intent or the expected energy performance

→ **Data should lead to decisions, not graphs**

- Energy management systems are producing so much data that we struggle to see the picture. Insight is needed.

iSERVcmb aims



→ iSERVcmb end goals:

- Contribute to a European framework for describing, monitoring and benchmarking HVAC system components against the activities they serve on a continuous basis
- Establish a first version of these benchmarks derived from monitored energy use
- Highlight HVAC solutions that achieve low energy in use
- Allow the HVAC sector and end users to take responsibility for reducing HVAC energy use long-term.
- Reward good behaviour by reducing the legislative burden for HVAC systems and buildings which meet benchmarks

Anticipated iSERV project outputs and impacts



- Establish iSERV approach as a complement to Inspection
- Allow end users to access ECOs specific to their HVAC systems
- Reward good system design and operation
- **Electricity savings between 5 – 60% per system anticipated**
- **Electricity savings of between 5 – 15% on average**
- Savings expected to be maintained c.f. Inspection reductions
- Establish that end users and manufacturers can help meet energy reduction goals when allowed to participate in setting targets to be achieved
- CIBSE and REHVA to use this information to produce professional guidance.

Appropriate benchmarks of energy performance



- ➔ Past energy benchmarks have been vague to reflect the difficulty of obtaining energy use data, as well as the relative unimportance of energy in the operation of an organisation
- ➔ This situation no longer exists and, as we move towards requiring nZEB buildings in the near future, it is time to revisit the benchmarks needed to achieve this target.
- ➔ The equation shown previously clearly implies that a **benchmark system should relate energy use to the activity undertaken in a space**, along with an indicator of the overall 'size' of the activity – usually floor area.
- ➔ Weather conditions are likely to be required, but the building itself is considered part of the efficiency opportunities

Practical benchmarks



- ➔ Legislative drivers and signals are important in affecting energy use in practice as they require compliance.
- ➔ What we struggle with at present is providing practical, 'legislation friendly' benchmarks for the energy efficiency possible in buildings **with a specific mix of end use activities**
- ➔ If we cannot provide this information then widespread nZEB 'in use' buildings will not be realisable by 2019.
- ➔ Discussions are underway with the EU on how iSERV will contribute to these benchmarks.

A PRACTICAL PROCEDURE FOR BENCHMARKING ENERGY USE IN HVAC SYSTEMS

The iSERVcmb process



- ➔ In a previous slide we noted that energy management and energy accounting should logically be split into two areas:
 - Energy used by the occupants and their activities
 - Energy used to service these activities
- ➔ This requires benchmark ranges for:
 - The energy consumed by the activities undertaken in the spaces i.e. small power, lighting and process load benchmarks
 - The HVAC services in meeting the requirements of those activities i.e. HVAC component benchmark by activity
- ➔ iSERVcmb provides a process and procedure for describing the spaces/activities plus meter and services arrangements in a building to acquire some of these benchmarks across the EU

iSERV Partners and Steering Group



<p>Welsh School of Architecture, Cardiff University Building energy use experts</p>		<p>K2n Ltd Energy database experts</p>	
<p>MacWhirter Ltd Installation, Maintenance and Energy Inspections</p>		<p>National and Kapodistrian University of Athens Indoor Air Quality experts</p>	
<p>University of Porto HVAC and Engineering experts</p>		<p>Politecnico di Torino HVAC and Engineering experts</p>	
<p>Université de Liège HVAC and Modelling experts</p>		<p>Univerza v Ljubljani HVAC and Engineering experts</p>	
<p>University of Pecs HVAC and Engineering experts</p>		<p>Austrian Energy Agency Dissemination and Legislation</p>	
<p>REHVA HVAC Professional Body</p>		<p>CIBSE HVAC Professional Body</p>	
<p>SKANSKA Building Developer</p>		<p>Camfil Farr Filter manufacturer</p>	
<p>SWEGON AHU System manufacturer</p>			

iSERV data basics




- ➔ iSERV collates information in a way that is rarely done for HVAC systems at present:
- It catalogues the HVAC components, meters and sensors
 - It describes the spaces, areas and activities served by the HVAC systems
 - It links all these elements together to describe the HVAC system components in terms of areas and activities served
 - It provides a web-based system to collate all this information and to receive the sub-hourly metered data to describe the HVAC systems' on-going performance.

The iSERV setup process



Connect the HVAC systems to the iSERV system and describe the spaces they are connected to




iSERV data entry sheet




- ➔ Part of the iSERV Excel-based data entry sheet is shown below
- ➔ The sheet is endorsed by CIBSE and REHVA as an accepted means of recording information about HVAC systems

Data applies from this date (dd/mm/yyyy):			Validate					
Building								
Building Name*	Description	Organisation Name*	Site Name*	Sector*	Address*	Town*	Postcode*	Country*
				<Ctrl-↓>				<Ctrl-↓>
Utility Meter							Add a Meter	
Name*	Description	Meter Type*	Unit Type*	Multiplier	Space Where Located	Unique Meter Id*	Parent Meter Name	
		<Ctrl-↓>	<Ctrl-↓>				<Ctrl-↓>	
HVAC Sensor							Add a Sensor	
Name*	Description	Sensor Type*	Unit Type*	Duct/Pipe Area m2	Unique Sensor Id*			
		<Ctrl-↓>	<Ctrl-↓>					
HVAC System							Add a HVAC System	
Name*	Description	Main HVAC System*	HVAC Type*	System Classification*	System Sub-classification*	Sensor Name(s)	Meter Name(s)	Control Of Flow Temperature
		<Ctrl-↓>	<Ctrl-↓>	<Ctrl-↓>	<Ctrl-↓>	None	None	<Ctrl-↓>
HVAC Component							Add a HVAC Component	
Name*	Description	Component Type*	Component Sub-type*	Serves which HVAC System(s)*	Space Where Located	Or* but preferably both if available		
		Pumps	<Ctrl-↓>	<Ctrl-↓>		Nominal Electrical Power Input (KW)	Meter Name(s)	Sensor Name(s)
							<Ctrl-↓>	<Ctrl-↓>
Schedules of Setpoint and Occupation							Add a Schedule	
To configure the schedule details please enter dates into the applies from or applies to cells below and then double click - this will take you to the schedule on the schedules tab								
Name*	Description	Range 1 - Applies From*	Range 1 - Applies To*	Range 2 - Applies From	Range 2 - Applies To	Range 3 - Applies From	Range 3 - Applies To	Range 4 - Applies From
Schedule 1 - Whole Building		01/01/2012	31/12/2012					
Space							Add a Space	
Name*	Description	Floor Area (m2)*	Height (m)	Sector*	Activity*	Served By HVAC(s)	Utility Meter(s)	Schedule of Setpoints, RH and Occupancy
				<Ctrl-↓>	<Ctrl-↓>	<Ctrl-↓>	<Ctrl-↓>	Schedule 1 - Whole Building

Overview of whole process



Excel sheet




**Meter/
sensor
data**



**Utility costs/
tariffs -
GBP/EUR/etc**


**iSERV web
database
and
analysis
software**



Reports



ECOs



Benchmarks





BENCHMARKS FOR HVAC ENERGY USE

Deriving benchmarks





- iSERV derives benchmarks by collecting and collating energy use data from HVAC component types servicing the same end use activity in different buildings and areas
- This data then provides ranges of achieved performance **by component** for a given activity
- Benchmark thresholds are initially set at the upper and lower quartiles of this data



Makeup of a benchmark for an activity



- The graphs show ranges of installed capacity and monitored energy use for AHU's used in cellular offices in multiple occupation
- By adding together all the components of an HVAC system serving an activity and area in a specific building, we can assemble an overall HVAC benchmark for a space or collection of spaces



iSERV benchmark types



- ➔ It is intended to produce ranges of benchmarks by activity at the levels of:
 - Annual energy consumption per m^2 ($kWh/m^2.a$)
 - Monthly energy consumption per m^2 ($kWh/m^2.month$)
 - Peak and average power consumptions in use (W/m^2)
- ➔ Initially, range boundary figures for the upper and lower quartiles of the measured data will represent the boundaries between 'good': 'average' and 'average': 'needs inspection' energy performance
- ➔ The wording of the performance 'achieved' may change to reflect actions needed

Use of benchmarks



- These 3 different benchmarks cover various possibilities for assessing energy use from the recorded data
- The normalised annual energy use is likely to be the benchmark for legislation
- The monthly energy use and power benchmarks are the most useful for diagnosing Energy Conservation Opportunities
- As these benchmarks are obtained from buildings in use from around Europe they represent what can be **achieved** in buildings at this moment in time.
- This makes them powerful in terms of setting realistic legislation standards for expected performance of HVAC system energy use in 'as-built' buildings

Initial HVAC components, lighting and small power benchmarks



- ➔ An initial set of installed power and annual energy use benchmarks by activity for AHU's, Chillers, CHW Pumps, HW Pumps, DHW Pumps, Humidifiers, Boilers, Lighting and Small Power is being assembled from existing sources and collected data.
- ➔ Complete by mid-September 2012, this data will be used to obtain the first bespoke benchmark ranges for those buildings and HVAC systems supplying data to iSERV

August 2012 HVAC components, lighting and small power benchmarks by activity and floor area. Max, 75%, Average, 25% and Min table

Table ranges from all data collected to August 2012	Air Handling										Chillers					
	max	75%	average	25%	min	max	75%	average	25%	min	max	0.75	average	0.25	min	max
	Installed power by activity served - W/m2					Activity electrical-energy use - kWh/m2.a					Installed power by activity served - W/m2					
iSERV Activity																
Car Park (Office/Private)	19	15	9	7	3	63	49	28	20	5	0	0	0	0	0	0
Car Park (Public)	39	31	17	14	6	241	184	107	69	12	0	0	0	0	0	0
Circulation area (corridors and stairways)	23	17	5	6	0	41	31	8	10	0	76	58	17	21	3	62
Lifts	23	17	5	6	0	41	31	8	10	0	76	58	17	21	3	62
Escalators	23	17	5	6	0	41	31	8	10	0	76	58	17	21	3	62
Reception	23	17	5	6	0	41	31	8	10	0	76	58	17	21	3	62
Waiting Rooms	42	32	9	11	1	140	106	24	37	3	76	59	27	25	8	62
Cellular Office Area	23	18	9	7	1	76	58	21	21	3	76	59	24	25	8	62
Cellular Office Area - multiple occupation	23	18	9	7	1	76	58	21	21	3	76	59	24	25	8	62
Consulting/treatment room	23	18	9	7	1	76	58	21	21	3	76	59	24	25	8	62
Open Plan Office Area	42	32	9	11	1	140	106	24	37	3	76	59	27	25	8	62
Lounges	42	32	9	11	1	140	106	24	37	3	76	59	27	25	8	62
Meeting Room	58	44	13	15	1	180	136	34	47	3	76	59	31	25	8	62
Library - reading room	65	50	13	18	3	270	204	49	72	6	78	63	38	32	17	58
Library - open stacks	18	14	6	5	1	69	52	21	19	2	78	60	29	24	6	39
IT: High Density IT Suite	0	0	#DIV/0!	0	0	0	0	#DIV/0!	0	0	0	0	#DIV/0!	0	0	0
IT: LAN Rooms	11	8	3	3	1	93	70	26	24	1	657	503	266	194	40	2335
IT: Server Room	52	39	3	13	1	93	70	26	24	1	127	105	79	62	40	844
Catering: Bars	29	23	16	11	5	131	103	73	46	18	71	59	39	36	24	63
Catering: Eating/drinking area	58	44	13	15	1	180	136	34	47	3	76	59	31	25	8	62
Catering: Full Kitchen Preparing Hot Meals	134	109	112	58	32	600	480	500	240	120	308	263	196	174	129	165
Catering: Limited Hot Food Preparation Area	29	23	16	11	5	131	103	73	46	18	71	59	39	36	24	63
Catering: Kitchenette (small appliances, fridge and sink)	47	37	19	16	6	100	77	44	31	8	66	56	40	36	26	19
Catering: Snack Bar with Chilled Cabinets	47	37	19	16	6	100	77	44	31	8	66	56	40	36	26	19
Catering: Vending Machines	47	37	19	16	6	100	77	44	31	8	66	56	40	36	26	19
Lecture theatre	78	61	34	27	11	140	108	61	44	12	117	99	69	63	45	34
Assembly areas / halls	34	26	11	10	3	56	43	19	16	3	45	37	23	22	14	16
Teaching Areas	35	27	13	11	4	60	46	23	19	5	51	43	25	26	17	17
Spectator area (theatres and event buildings)	19	15	4	5	1	63	48	13	17	2	32	26	13	13	7	36
Stage (theatres and event buildings)	3	2	1	1	0	7	5	2	2	0	92	73	36	35	16	146
Bathroom	5	4	4	3	2	16	14	13	9	7	51	43	24	26	17	11
Toilet	5	4	4	3	2	16	14	13	9	7	51	43	24	26	17	11

REPORTING ENERGY USE AND ECOS IN HVAC SYSTEMS

Making sense of the data



- ➔ iSERV will process the information provided to the database by individual systems to produce:
 - Bespoke benchmarks per HVAC component and system
 - Clear reports – including benchmark and exception reports
 - Suggestions for Energy Conservation Opportunities
- ➔ From analysing the data for the 1600+ HVAC systems iSERV will also:
 - Note what ‘works’ in practice – technology neutral
 - Produce on-going benchmarks over time for use in legislation and professional guidance
 - Update and add to the ECO’s

Prototype reports




- ➔ The following slides illustrate the types of report which can be derived from the iSERV system.
- ➔ These are prototype reports at present and further report types will emerge as the data analysis reveals how best to achieve efficiency in system operation
- ➔ In particular it is anticipated that the following report types will become available:
 - Separate reports aimed at the occupants and services operators.
 - Cost-based reports aimed at finance managers
 - Carbon-based reports for compliance purposes
 - Reports aimed at the EPBD Inspection process needs

HVAC System Report



➔ Overview of whole HVAC system performance against bespoke benchmarks predicted for mix of activities served




HVAC Component Reports



→ Individual HVAC component normalised annual energy use against energy use ranges predicted by component for the mix of activities served

Component Level Electricity Consumption in kWh/m²/year against benchmark



Energy Conservation Opportunity (ECO) Reports



- ➔ Another unique feature of iSERV is its ability to take the measured data for the HVAC components along with other characteristics of the HVAC components and spaces, and suggest potential ECOs that could reduce the energy use of the specific HVAC system.
- ➔ iSERV will provide an indication of the likely energy, carbon and cost savings to be achieved for each ECO.
- ➔ ECO reports maximise the value of submeters, and help reduce the analysis time needed by the energy manager to understand his HVAC system.

Example outputs from iSERV data

– ‘standard’ monthly use data




McKenzie House Conditioned Floor Area/m2 = 8434.93

All Figures in kWh/m2

Month	Electricity - Unallocated consumption	Chillers	Roof Plant Power	LAN Room AC Power	Boiler Room Power
Mar-11	3.62	0.18	1.54	0.21	0.67
Apr-11	3.10	0.38	1.17	0.21	0.21
May-11	3.49	0.18	0.93	0.21	0.13
Jun-11	3.39	0.39	1.09	0.18	0.11
Jul-11	3.29	1.24	1.33	0.17	0.11
Aug-11	3.36	0.98	1.32	0.17	0.11
Sep-11	3.25	0.50	1.12	0.16	0.11
Oct-11	3.33	0.15	1.13	0.17	0.25
Nov-11	3.36	0.11	1.37	0.16	0.48
Dec-11	3.17	0.06	1.30	0.17	0.52
Jan-12	3.34	0.05	1.45	0.16	0.55
Feb-12	3.37	0.07	2.16	0.16	0.90

Sum of Std_Month Consumption	L Total Mar-11 to Feb-12	40.1	4.3	15.9	2.1	4.1	13.3	0.8	45.0	125.7	257.0
------------------------------	--------------------------	------	-----	------	-----	-----	------	-----	------	-------	-------

McKenzie House Electricity Breakdown by Month




Month	Clean			DB Floors		DB Ground cum power	Fire Panel cum power	Lan Room AC cum power	Landlords DB cum power	Lift 1 cum power	Lifts 2&3 cum power	Main Incomer CP	MCP 4th Plant cum power	MCP Boiler Plant cum power	MCP Central services	MCP Dining cum power			
	Blr 1 Cumulative	Blr 2 Cumulative	Blr 3 Cumulative	Chiller 1 cum power	Chiller 2 cum power												Supply DB cum power	DB Floor 2 cum power	1&3 cum power
Mar-11	5,956.81	316,373.75	9,614.31	986	561	37	-	10,993	-	1	1,792	-	206	253	99,253	207	5,623	567	622
Apr-11	2,919.58	18,340.97	3,903.47	1,846	1,374	47	-	9,154	-	1	1,734	-	1	412	81,365	177	1,772	534	628
May-11	791.39	3,443.61	1,058.75	1,042	464	49	-	9,661	-	1	1,792	-	24	490	82,732	188	1,062	561	859
Jun-11	-	-	-	1,868	1,382	12	-	9,904	-	1	1,543	-	249	416	85,947	176	907	574	559
Jul-11	-	-	-	5,326	5,092	22	-	9,299	-	2	1,400	-	276	388	92,747	185	930	537	488
Aug-11	-	-	-	4,555	3,730	1	-	9,455	-	-	1,401	-	259	371	91,448	182	961	560	548
Sep-11	224.58	224.58	-	2,561	1,651	13	-	9,341	-	2	1,356	-	270	382	84,318	177	935	542	529
Oct-11	2,481.11	246,988.19	3,443.61	806	498	17	-	9,422	-	1	1,403	-	272	378	83,722	185	2,079	536	514
Nov-11	4,320.56	73,631.25	6,523.61	561	354	10	-	10,019	-	1	1,358	-	282	403	88,882	179	4,018	541	523
Dec-11	242,218.47	294,749.58	12,533.89	288	189	110	-	7,816	-	2	1,402	-	217	305	80,854	198	4,373	522	556
Jan-12	71,075.28	266,901.25	10.69	261	190	145	-	8,854	-	1	1,359	-	252	364	87,521	215	4,628	498	515
Feb-12	277,756.11	76,197.92	225,684.86	316	234	109	-	10,176	-	2	1,362	-	277	407	101,491	248	7,620	510	534
Mar-12	19,378.33	20,982.50	19,378.33	93	58	46	-	3,337	-	-	454	-	89	133	30,778	63	2,577	165	175
Grand Total	627,122.22	1,317,833.61	282,151.53	20,509	15,777	618	-	117,431	-	15	18,356	-	2,674	4,702	1,091,058	2,380	37,485	6,647	7,050

Example outputs from iSERV data – subhourly data




➔ Example for Chiller 1 for July 2011 showing good time control compared to occupancy hours



Energy use by component




- iSERV will calculate the consumption of individual HVAC components PER UNIT AREA SERVED and PER ACTIVITY where the component supply meter is recorded.
- This information is the basis of the on-going benchmarks to be produced by iSERV



Energy cost by activity




- Energy cost by activity can be calculated for the whole building energy consumption (monthly cost shown here)
- This can also be broken down into HVAC and Occupant costs by activity per month



Energy cost by space



➔ These costs can be assigned by space as well based on the main activity in a space. Here total costs are again shown



Resume



- ➔ iSERV is working with the main actors across Europe to produce, evaluate and demonstrate a monitoring and feedback approach to reducing energy use in HVAC systems as now allowed by the EPBD
- ➔ All the indications to date are that the approach will produce significant energy savings as it clarifies and benchmarks an organisations activities and supporting services
- ➔ This provides confidence and a framework to evaluate and prioritise investment in energy efficiency by the end user
- ➔ The project will also provide benchmarks to which national legislation can refer for this type of approach

PARTICIPATING IN ISERV

Participation in iSERV



- ➔ iSERVcmb is an important opportunity for everyone involved in reducing the energy consumption of buildings to contribute towards setting these new standards.
- ➔ iSERV is recruiting around 1600 HVAC systems to participate in helping set these standards.
- ➔ Data is required for all types of activities and HVAC components.
- ➔ iSERV has an Excel template, previously shown, for entering the required data for a building to participate in iSERVcmb. This template is also endorsed by CIBSE for collating data about HVAC systems, meters and spaces for mandatory Inspection purposes.

iSERV – direct end user benefits



- ➔ Offers all HVAC system operators the opportunity to trial for free a monitoring and feedback approach to energy efficiency across their HVAC systems. iSERV:
- Deals with the data overload problem arising from trying to handle the outputs from many submeters in the building
 - Links energy use @ HVAC component level to the activities served
 - Provides regular feedback to help maintain savings achieved
 - Provides analysis of monitored data and feedback on not only consumption achieved against benchmarks but also potential Energy Conservation Opportunities (ECOs).
 - Reduces staff time spent analysing data freeing it up for implementing practical energy conservation regimes
 - Will put monetary figures to all this data where possible

iSERV – indirect end user benefits



- ➔ CIBSE and REHVA will publish benchmarks produced from iSERV as professional guidance i.e. the approach should become the accepted way to operate HVAC systems in practice across the EU. Participation therefore enables early experience to be gained
- ➔ Ability to highlight participation as part of CSR
- ➔ Help establish the principle that a demonstrably good energy consumption for an HVAC system should be acceptable as an alternative to prescriptive legislation – with legislation only being invoked where performance does not meet bespoke standards

How to participate in iSERV



- ➔ Register on the iSERV website – www.iservcmb.info
- ➔ Notify the relevant iSERV Partner that you wish to participate, so that you have the latest information
- ➔ Download the iSERV spreadsheet and complete it for your HVAC system(s) by building.
- ➔ Validate the spreadsheet and send to iSERV for checking and entering to iSERV database
- ➔ Check and validate your data collection with iSERV
- ➔ Start using iSERV to help manage your HVAC system

Project period



- ➔ iSERVcmb runs until May 2014 and provides a free to use resource for building owners. At least one similar solution will be offered post-project to continue collating benchmarks
- ➔ Participation in iSERVcmb will:
 - Provide bespoke HVAC benchmarks for the buildings entered,
 - Allow participants to advertise their assistance in helping set UK and European standards in this area, as well as helping to influence future EU energy efficiency policy.
 - Anonymity of data is provided unless otherwise required.
- ➔ We are looking for around 100 – 200 HVAC systems in the UK and have around 30 signed up at present. The project should appeal to well monitored Estates.

iSERV Summary



- ➔ iSERV will produce 'benchmark' figures at HVAC component and activity level for the professions
- ➔ iSERV is the only large-scale 'open' approach to this area at present in Europe
- ➔ 'Blind' to manufacturer and other potential bias
- ➔ Allows rapid verification of novel HVAC approaches in real buildings
- ➔ Allows owners to fully understand their systems
- ➔ Essential for understanding HVAC system energy use in time to allow an orderly transition to nZEB



**Inspection of
HVAC systems
through
continuous
monitoring and
benchmarking**

www.iservcmb.info

**Thank you for your
attention**

Dr Ian Knight
iSERV Coordinator
knight@cf.ac.uk
www.iservcmb.info